



Tentative Interim Amendment

NFPA[®] 2001

Standard on Clean Agent Fire Extinguishing Systems

2012 Edition

Reference: 4.2.1.1.2, 4.2.1.1.3, A.4.2.1.1.2, and A.4.2.1.1.3

TIA 12-1

(SC 12-10-10/TIA Log #1069)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*, 2012 edition. The TIA was processed by the Technical Committee on Gaseous Fire Extinguishing Systems, and was issued by the Standards Council on October 30, 2012, with an effective date of November 19, 2012.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Add new sections to read as follows:

4.2.1.1.2* For systems that employ the use of a pressure-reducing device, the minimum design pressure for piping downstream of the pressure reducer shall be determined by system flow calculations.

4.2.1.1.3* Piping for pre-engineered systems shall be designed in accordance with the limitations of the manufacturer's listed installation manual.

A.4.2.1.1.2 The pressure reduction of the system discharge may be accomplished through the system's cylinder valve or through a separate pressure-reducing device.

A.4.2.1.1.3 Pre-engineered systems are designed to listed limitations which may or may not include values for pressures downstream of pressure reducers.

Issue Date: October 30, 2012

Effective Date: November 19, 2012

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)

Copyright © 2012 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION