



Errata

NFPA 75

Standard for the Fire Protection of Information Technology Equipment

2013 Edition

Reference: 8.1.1.3 and 8.1.1.4

Errata No.: 75-13-1

The Committee on Electronic Computer Systems notes the following errors in the 2013 edition of NFPA 75, *Standard for the Fire Protection of Information Technology Equipment*.

1. Add new 8.1.1.3 and 8.1.1.4 to read as follows:

8.1.1.3 Where a gaseous fire extinguishing system is provided only under a raised floor, the gaseous system shall be either carbon dioxide or an inert gas.

8.1.1.4 Where a clean agent fire extinguishing system is provided to protect the space above the raised floor, the space under the raised floor shall be simultaneously protected by the clean agent fire extinguishing system.

Issue Date: May 22, 2013

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see <http://www.nfpa.org/docinfolist>)

Copyright © 2013 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION