



DICHIARAZIONE DI PRESTAZIONE

N. 0051-CPR-0230

Codice di identificazione unico del prodotto-tipo:

SmartLine020-2

Uso/i previsti:

**Centrale di controllo e segnalazione con apparecchiatura di alimentazione integrata
per sistemi di rivelazione e di segnalazione d'incendio per edifici**

Fabbricante:

INIM ELECTRONICS S.R.L.**Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - Italy**

Sistema/i di VVCP:

Sistema 1

Norma/e armonizzate:

EN 54-2:1997 + A1:2006**EN 54-4:1997 + A1:2002 + A2:2006**

Organismo/i Notificati:

IMQ S.p.A., N. 0051

Prestazione/i dichiarate:

Caratteristiche essenziali	Prestazione	Specifica tecnica armonizzata	§	Note
Prestazioni in caso d'incendio				
Requisiti generali	PASS	EN 54-2:1997 + A1:2006	4	
Requisiti generali per le segnalazioni	PASS		5	
Condizione di allarme incendio	PASS		7	
Prestazione di alimentazione				
Requisiti generali	PASS	EN 54-4:1997 + A1:2002 + A2:2006	4	
Funzioni	PASS		5	
Materiali, progetto e costruzione	PASS		6	
Ritardo nella risposta (tempo di risposta all'incendio)				
Ricezione ed elaborazione di segnali d'incendio	PASS	EN 54-2:1997 + A1:2006	7.1	
Uscita in condizione di allarme incendio	PASS		7.7	
Uscita verso i dispositivi di allarme incendio (opzione con requisiti)	PASS		7.8	
Comando dei dispositivi di trasmissione di allarme incendio (opzione con requisiti)	PASS		7.9	
Ritardo delle uscite (opzione con requisiti)	PASS		7.11	
Correlazione su più di un segnale d'allarme (opzione con requisito)	PASS		7.12	Tipo A e B
Affidabilità di funzionamento				
Requisiti generali	PASS	EN 54-2:1997 + A1:2006	4	
Requisiti generali per le segnalazioni	PASS		5	
Condizione di riposo	PASS		6	
Condizione di allarme incendio	PASS		7	
Condizione di guasto	PASS		8	
Uscita verso l'apparecchiatura di segnalazione remota di guasto e avvertimento (opzione con requisiti)	PASS		8.9	
Condizione di fuori servizio	PASS		9	
Condizione di test (opzione con requisiti)	PASS		10	
Interfaccia normalizzata ingresso/uscita (opzione con requisiti)	NPD		11	



Requisiti costruttivi	PASS		12	
Requisiti costruttivi aggiuntivi per apparecchiature di comando e segnalazione controllate mediante software	PASS		13	
Marcatura	PASS		14	
Requisiti generali	PASS		4	
Funzioni	PASS		5	
Materiali, progetto e costruzione	PASS	EN 54-4:1997 + A1:2002 + A2:2006	6	
Documentazione	PASS		7	
Marcatura	PASS		8	
Durabilità dell'affidabilità di funzionamento: resistenza termica				
Freddo (prova funzionale)	PASS	EN 54-2:1997 + A1:2006	15.4	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.5	
Durabilità dell'affidabilità di funzionamento: resistenza alle vibrazioni				
Urto (prova funzionale)	PASS	EN 54-2:1997 + A1:2006	15.6	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.7	
Vibrazioni sinusoidali (prova funzionale)	PASS	EN 54-2:1997 + A1:2006	15.7	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.8	
Vibrazioni sinusoidali (prova di durata)	PASS	EN 54-2:1997 + A1:2006	15.15	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.15	
Durabilità dell'affidabilità di funzionamento: stabilità elettrica				
Compatibilità elettromagnetica (EMC) prove di immunità (prova funzionale)	PASS	EN 54-2:1997 + A1:2006	da 15.8 a 15.13	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	da 9.9 a 9.13	
Durabilità dell'affidabilità di funzionamento: resistenza all'umidità				
Caldo umido, continuo (prova funzionale)	PASS	EN 54-2:1997 + A1:2006	15.5	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.6	
Caldo umido, continuo (prova di durata)	PASS	EN 54-2:1997 + A1:2006	15.14	
	PASS	EN 54-4:1997 + A1:2002 + A2:2006	9.14	

La prestazione del prodotto sopra identificato è conforme all'insieme delle prestazioni dichiarate. La presente dichiarazione di responsabilità viene emessa, in conformità al regolamento (UE) N. 305/2011, sotto la sola responsabilità del fabbricante sopra identificato.

Firmato a nome e per conto del fabbricante da:

Baldovino Ruggieri
(Amministratore Delegato)

In Monteprandone, addì 07/11/2014

A PASSION for SECURITY



DECLARATION OF PERFORMANCE

No. 0051-CPR-0230

Unique identification code of the product-type:

SmartLine020-2

Intended use/es

**Control and indicating equipment with integrated power supply equipment
for fire detection and fire alarm systems installed in buildings**

Manufacturer:

INIM ELECTRONICS S.R.L.

Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - Italy

System/s of AVCP:

System 1

Harmonized standard/s:

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

Notified Body/ies:

IMQ S.p.A., No. 0051

Declared performance/es:

Essential Characteristics	Performance	Harmonized technical specification	§	Note
Performance under fire conditions				
General requirements	PASS	EN 54-2:1997 + A1:2006	4	
General requirements for indications	PASS		5	
Fire alarm condition	PASS		7	
Performance of power supply				
General requirements	PASS	EN 54-4:1997 + A1:2002 + A2:2006	4	
Functions	PASS		5	
Materials, design and manufacture	PASS		6	
Response delay (response time to fire)				
Reception and fire signals	PASS	EN 54-2:1997 + A1:2006	7.1	
Output of the fire alarm condition	PASS		7.7	
Output to the fire alarm device (option with requirements)	PASS		7.8	
Control of fire alarm routing equipment (option with requirements)	PASS		7.9	
Delays to outputs (option with requirements)	PASS		7.11	
Dependencies on more than one signal (option with requirement)	PASS		7.12	Type A and B
Operational reliability				
General requirements	PASS	EN 54-2:1997 + A1:2006	4	
General requirements for indications	PASS		5	
The quiescent condition	PASS		6	
The fire alarm condition	PASS		7	
Fault warning condition	PASS		8	
Output to warning routing equipment (option with requirements)	PASS		8.9	
Disabled condition	PASS		9	
Test condition (option with requirements)	PASS		10	
Standardized input/output interface (option with requirements)	NPD		11	
Design requirements	PASS		12	



Additional design requirements for software controlled control and indicating equipments	PASS		13	
Marking	PASS		14	
General requirements	PASS		4	
Functions	PASS		5	
Materials, design and manufacture	PASS	EN 54-4:1997 + A1:2002 + A2:2006	6	
Documentation	PASS		7	
Marking	PASS		8	
Durability of operational reliability: temperature resistance				
Cold (operational)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.4 9.5	
Durability of operational reliability: vibration resistance				
Impact (operational)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.6 9.7	
Vibration, sinusoidal (operational)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.7 9.8	
Vibration, sinusoidal (endurance)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.15 9.15	
Durability of operational reliability: electrical stability				
Electromagnetic compatibility (EMC), immunity tests (operational)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	from 15.8 to 15.13 from 9.9 to 9.13	
Durability of operational reliability: humidity resistance				
Damp heat, steady state (operational)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.5 9.6	
Damp heat, steady state (endurance)	PASS PASS	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006	15.14 9.14	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Baldovino Ruggieri
(Managing Director)

At Montepredone, on 07/11/2014

A PASSION for SECURITY



DICHIARAZIONE DI CONFORMITA' CE

N. 0051-CPR-0230

Noi, **INIM ELECTRONICS S.R.L.**,

Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - Italy

dichiariamo sotto la nostra esclusiva responsabilità, che il prodotto

Modello: **SmartLine020-2**

Descrizione: **Centrale di controllo e segnalazione con apparecchiatura di alimentazione integrata per sistemi di rivelazione e di segnalazione d'incendio per edifici**

al quale si riferisce la presente dichiarazione, è conforme ai requisiti essenziali ed alle altre disposizioni pertinenti stabiliti dalla/e Direttiva/e:

2006/95/CE (LVD)
2004/108/CE (EMCD)

Il prodotto è conforme alle seguenti norme e/o ad altri documenti normativi:

EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013

EN 61000-6-3:2007 + A1:2011

EN 50130-4:2011

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

Anno di prima apposizione della marcatura CE: **2009**

La documentazione tecnica è conservata da INIM ELECTRONICS S.R.L.

Monteprandone, 07/11/2014

Firmato a nome e per conto del fabbricante da:

Baldovino Ruggieri
(Amministratore Delegato)



EC DECLARATION OF CONFORMITY

No. **0051-CPR-0230**

We, **INIM ELECTRONICS S.R.L.**,

Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - Italy

hereby declare under our sole responsibility, that the product

Model: **SmartLine020-2**

Description: **Control and indicating equipment with integrated power supply equipment for use in fire detection and alarm systems installed in buildings**

to which this declaration relates, is in conformity with the essential requirements and other relevant requirements of the Directive/es:

2006/95/EC (LVD)
2004/108/EC (EMCD)

The product is in conformity with the following standards and/or other normative documents:

EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013

EN 61000-6-3:2007 + A1:2011

EN 50130-4:2011

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

Year of first affixing of CE marking: **2009**

The technical file is kept by INIM ELECTRONICS S.R.L.

Monteprandone, 07/11/2014

Signed for and on behalf of the manufacturer by:



Baldovino Ruggieri
(Managing Director)