

**0845 – CPD–232.1688**

**EC-CERTIFICATE OF CONFORMITY**

Issued by Danish Institute of Fire and Security Technology. Notified body No. 0845

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

**STI IP67 WRP-R-01                      Manual Call Point for outdoor use, IP67**

for applications related to automatic fire alarm systems

placed on the market by

**STI (Europe)**  
**Unit 49G Pipers Road**  
**Park Farm Industrial Est., Redditch**  
**Worcestershire, B98 0HU**  
**England**

**Danish Institute of Fire and Security Technology**  
**CERTIFIED COPY**  
Signature: 

and produced in the factory

**STI (Europe)**  
**Unit 49G Pipers Road**  
**Park Farm Industrial Est., Redditch**  
**Worcestershire, B98 0HU**  
**England**

is(are) submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body Dansk Brand- og sikringsteknisk Institut (*DBI - Danish Institute of Fire and Security Technology*) has performed the initial type-testing for the relevant characteristics of the product(s), the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all the provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN54-11:2001                      Fire detection and fire alarm systems –  
Part 11: Manual Call Points


EN54-11:2001/A1:2005                      Fire detection and fire alarm systems –  
Part 11: Manual Call Points


were applied and that the product fulfils all the prescribed requirements.

The attached 2 annexes forms part of this certificate.

This certificate was first issued on 2010-10-04 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC it selves are not modified significantly.

This certificate supersedes earlier version of this certificate, issued 2010-04-19

  
Henning S. Albøge

  
Tom Nisted

*Annex: 1**Certificate no.: 0845 – CPD–232.1688**Date: 2010-10-04***TEST DOCUMENTATION**

<b>Accredited laboratory</b>	<b>Report no.</b>	<b>Date</b>
DELTA	DANAK-1910744 Rev. B Project no.: A530602	2010-10-01

Annex: 2

Certificate no.: **0845 – CPD–232.1688**

Date: 2010-10-04

### TECHNICAL BASIS

Document	Document Identity	Version	Date
Technical data for Waterproof ReSet Call Point Series 01, 02 & 11 (Enclosed the MPC's)	IDWaterproof-Reset_Series01,02&11	10/09-042	
Bills of Material List	WPR-R-01 Waterproof ReSet Series 01		15/08/2009
Label	WRP-R-01PCB_EN 54 terminal label.jpg		Signed by HSA 2010-04-13
Placement of the label	IMG00008-20091218-1313.jpg		18/12-2009